

## Short Form Classification Report No. 19614D

### PRODUCT

MAKROCLEAR, MAKROLIFE, COLORADO & COLORADO UV

### SPONSOR

ARLAPLAST AB

### PRODUCT DETAILS

- Type of product: MAKROCLEAR, MAKROLIFE, COLORADO & COLORADO UV
- Nominal thickness: 0,75 mm – 6 mm
- Nominal density: 1200 kg/m<sup>3</sup>
- Colour: all colours (including transparent) with a minimum light transparency of 26 %
- With or without UV protection layer
- Surface structure: Smooth

### FIELD OF APPLICATION

- Freestanding
- With edge finishing of at least Euro class A2-s1,d0 (protection of cut edges)
- Without joints

### CLASSIFICATION

**B-s1,d0**

### STANDARDS

Test standard: EN ISO 11925-2:2002 & EN 13823:2010+A1:2014

Classification standard: EN 13501-1:2007+A1:2009

SIGNED

APPROVED

*For and on behalf of WFRGENT nv*

This short form classification report has been drafted according to EGOLF agreement EGA 08rev2:2013 "Application note: clause 5.10 [5.10/1] – Types of test reports used in fire testing". Whilst the test data and classification provided within this short form report was obtained in a test conducted fully in accordance with the standards EN ISO 11925-2:2002, EN 13823:2010+A1:2014 & EN 13501-1:2007+A1:2009, the presentation of the results in this short form report may not satisfy the requirements of those standards and EN ISO/IEC 17025:2005/AC:2006. The presentation of the results in this manner is made by agreement with the sponsor and use of the information herein for product assessment, approval or certification purposes will be restricted.

The full classification report No. **19614B** is available at **ARLAPLAST AB**.

This document is the original version of this report and is written in English. This document may be used only literally and completely for publications. For publications of certain texts, in which this document is mentioned, our permission must be obtained in advance.

The authenticity of the electronic signatures is assured by Belgium Root CA.